

Enterprise Electric Co.**REQUEST FOR INFORMATION****No. 00001**4204 Shannon Drive
Baltimore, MD 21213**Phone:** 410-488-8200
Fax: 410-488-6639**TITLE:** Sample RFI**DATE:** 3/19/01**PROJECT:** General Information**JOB:****TO:** SAIC Frederick
Project Management & Engineering
P.O. Box B (Bldg 350)
Frederick, MD 21702-1201**STARTED:****COMPLETED:****ATTN:** James F Parsons PE**REQUIRED:** 3/26/01**REQUEST:**

This is an example of a Request for Information submitted by a contractor.

What is the Basic Insulation Level of the distribution system components?

Requested By: Enterprise Electric Co.**Date:** 3/19/01**Signed:** _____

Mr. Gary C. Beck

ANSWER:

The basic insulation level required by Fort Detrick is 15kV.

Answered by: SAIC**Date:** 3/22/01**Signed by:** _____FMEP-P-0305
Rev. 0
Exhibit B
Page 1 of 1